





Fluid Analysis Par-Test™

Fluid analysis has proven to be a critical tool for any preventive maintenance program. Fluid analysis is able to identify potential problems that cannot be detected by human senses.

A comprehensive fluid analysis program can help prevent major hydraulic or lube oil system failures.

Par-Test is a complete laboratory analysis, performed on a small volume of fluid. The report you receive is a neatly organized three page format. One may quickly analyze the test results of an

individual sample and/or look at a trend analysis for up to five different samples. Two types of services are offered through Par-Test, a water base fluid analysis kit or a petroleum base fluid analysis kit. For both types of services the Par-Test kit includes a pre-cleaned glass bottle, mailing container with pre-addressed label, sample information data sheet (to be completely filled out by end user) and the following analysis: Fluid sampling for Par-Test involves important steps to insure you are getting a representative sample. Often, erroneous sample procedures will disguise the true nature of the system fluid. A

> complete sampling procedure is detailed on the back of this brochure. There also is a National Fluid Power Association standard (NFPA T2.9.1-1972) and an American National Standards Institute Standard (ANSI B93.13-1972) for extracting samples from a fluid power system.



Petroleum Base Kit

Particle Count Photomicrograph Free Water Analysis Spectrometric Analysis Viscosity Analysis Water Analysis (PPM) Neutralization Analysis

Water Base Kit

Particle Count Photomicrograph Spectrometric Analysis Viscosity Analysis Neutralization Analysis

How to Order Description	Part Number		
Petroleum base fluid kit (single test bottle)	927292		
Petroleum base fluid kit (Carton of 10 test bottles)	927293		
Water base fluid kit (single test bottle)	932995		



Fluid Analysis Par-Test[™]

FLUID ANALYSIS REPORT PARTEST Fluid Analysis Service SAMPLE CODE: 93844 DATE: 09/01/04 Parker Hannifin Corpora 1016 E. Airport Rd. Stillwater, OK 74075 Tele: (405)624-0400 Fax: (405)624-0401 Parker Hannifan 16810 Fulton Rd. Co #2 Metamora, OH, 43540 יהר גרי ATTN: Kevin Noe COMPANY NAME: ABC Corporation SAMPLE DATE: 7/12/2004 SYSTEM TYPE: HOURS: (on oil) 948 (on unit) 2000 Hydraulic EQUIPMENT TYPE: SYSTEM VOLUME: 200 Gallons Press MACHINE ID: Machine #1 FLUID TYPE: AW 44 FILTER ID: Parker 10 micron ANALYSIS PERFORMED: N2.5.T.V4.W **AUTOMATIC PARTICLE COUNT ISO 11171** 30 FREE 5.0 4.0 3.0 WATER 29 Size Counts per ml. ISO Code PRESENT 2.0 1.5 10⁶ 28 >4 µm(c) 35000.0 >6 µm(c) >10 µm(c) >14 µm(c) >21 µm(c) 27 15498.0 6000.0 2600.0 **YES** 5.0 4.0 3.0 22/21/19 1468.0 25 2.0 >38 µm(c) >50 µm(c) 754.0 58.0 X NO 105 >70 µm(c) 3.0 23 5.0 4.0 3.0 22 2.0 PHOTO ANALYSIS 21 10 Mag.: 160x Scale: 1 div = 20 µm Vol 20m 20 5.0 4.0 3.0 19 20 18 103 17 5.0 16 60 15 2.0 10 14 13 5.0 4.0 3.0 12 2.0 11 10 5.0 4.0 3.0 9 2.0 8 10 7 5.0 4.0 3.0 2.0 10 4 5.0 4.0 3.0 2 ALARMS/REMARKS 1 H 10 *The red line in the ISO chart graph indicates recomm ed cleanliness level 15 20 2530 40 50 60 80 Size (µm)

Photo Analysis

A photomicrograph of a small volume of fluid (20 ml) magnified 100X. This analysis gives a quick glance at the contamination present in the fluid. Each line of the graduated scale represents 20 microns in size.

The full color photomicrograph helps identify particles which would otherwise be grouped by class.

ISO Chart

Graphically illustrates the particle count on a graph. The recommended cleanliness code level, if given on the submittal form, is shown by a broken line on the ISO chart.



Sample Data

Information supplied by the user regarding the fluid to be analyzed. Complete and accurate information is crucial for a useful analysis.

Particle Count

Results are reported over 6 different particle size ranges and expressed as an ISO code (modified). The counts are per milliliter of fluid and the reporting is cumulative; ie. The particle count in the >2 micron row includes the number of particles greater than 5, 10, 15, 25 and 50 microns as well as particles between 2-5 microns in size. Particle resuspension method is utilized for water based fluid samples.


Free Water Analysis

Determines if the water present is beyond the saturation point of the fluid. At the saturation point, the fluid can no longer dissolve or hold any more water. Its appearance becomes cloudy or "milky". Many hydraulic oils saturate between 500 and 1000 PPM of water.



Fluid Analysis

Par-Test[™]



Iron: Ferrous wear particle typically from pumps, gears, cylinders, or rust	Calcium: Dispersant a Phosphorous: Anti-we
Copper: Brass (copper/zinc) and bronze (copper/tin) in bearings and bushings	in fluid Barium: Corrosion, ru
Chromium: (white non ferrous metal) Chrome from cylinder rods, bearings, valve spools	Boron: Detergent, dis
Lead: Babbitt or copper lead bearings	Sodium: Detergent or
Aluminum: White nonferrous metal from pump bodies, bushings, bearings, and	Molybdenum: Alloy m additive
grinding compounds	Silver: White non ferro
Tin: Babbitt bearings, plating	Nickel: Alloy metal

WEAR METALS AND ADDITIVES

Silicon: Sand/dirt contamination or antifoaming additive in oil

- Zinc: Plating or anti-wear additive in oil
- Magnesium: Detergent, dispersive additive in oil, bearings, water

- additive or acid neutralizer ear or fire resistant additive
- ust inhibitor additive in oil
- spersive additive in oil r coolant additive
- netal or anti friction
- rous meta
- Nickel: Alloy metal
- Titanium: White non ferrous metal
- Manganese: White non ferrous metal

Antimony: Babbit bearings, greases

Viscosity is a very important property performance. Viscosity expresses the internal friction between molecules in the fluid. Typically a breakdown in viscosity will be seen as an increase. Both SSU at 100° F and cSt at 40° C

Referred to as the Total Acid Number (TAN) this titration test measures the acid level of the sample fluid. The production of acidic material causes oxidation degradation or aging of most fluids. This activity is promoted by elevated temperatures, presence of entrained metal particles, and intimate contact with air. It is the rate of increase of the TAN during any given time period that is significant,

Karl Fischer test gives accurate measure of water concentration in the sample fluid. The results are reported in parts per million (PPM) and allow for detection of water levels well below the

Quick statements or alerts about any unusual results from one of the tests reported on this page.

Spectrometric Analysis

Results obtained by Rotating Disk Electrode (ROE) Spectrometer and reported in terms of parts per million (PPM). Twenty different wear metals and additives are analyzed to help determine the condition of the fluid. The spectrometric test is limited to identifying particles below 5-7 micron in size. Base line (new) fluid samples should be sent in for each different fluid to be analyzed. This will be used to determine the status.



Fluid Analysis Par-Test™

For our Par-Test™ customers, **FLUID ANALYSIS REPORT** the analysis report is available online for your ease and PARTEST Fluid Analysis Service SAMPLE CODE: 93844 DATE: 09/01/04 Parker Hannifin Corporation 1016 E. Airport Rd. Stillwater, OK 74075 Tele: (405)624-0400 Fax: (405)624-0401 convenience. Historical Parker Parker Hannifan 16810 Fulton Rd. Co #2 Metamora, OH, 43540 data is also available. Visit www.partestlab.com ATTN: Kevin Noe 7/ ---Parker ISO CODE 30 5.0 4.0 3.0 **Trend Analysis** 29 2.0 1.8 10⁶ 28 Graphical history for up to 27 5 samples plotted for 2, 5 5.0 4.0 3.0 1.5 10⁵ 26 and 15 micron and greater 25 24 size particles. This analysis 23 5.0 4.0 3.0 is a valuable tool for tracking 22 NUMBER 2.0 1.5 10⁴ the progress of a system 21 20 over a given time period. 5.0 4.0 19 0 F 2.0 1.5 **10³** Legend: 18 >4 Micron 17 PARTICLES >6 Micron 5.0 4.0 16 >14 Micron 0 **ISO Range Code** 15 4 micron target 18 2.0 1.5 10² 14 6 micron target 16 Index Number that is 13 14 micron target 14 5.0 4.0 associated with a range 12 P E R 2.0 1.5 10¹ 11 of particles. Below is a list MILLILITER 10 of the range numbers and 5.0 4.0 3.0 9 the corresponding particle 2.0 1.5 10⁰ 8 7 quantities. 5.0 4.0 3.0 6 5 2.0 1.8 **10**1 4 3 5.0 4.0 3.0 Sample Code 2 2.0 1.5 **10**² Assigned to the test kit form for a ready reference. This DATE code can be used to track the 7/6/2004 7/12/2004 PARTICLES > 4 MICRON S 457895 35000 sample from start to finish. PARTICLES > 6 MICRON S 231456 15498 PARTICLES > 14 MICR ONS 6210 2600 ISO CLEANLINESS CODE 26/25/20 22/21/19 SAMPLE CODE 93843 93844

NUMBER OF PARTICLES PER ML						
Range Code	More than	Up to and including	Range Code	More than	Up to and including	
30	5,000,000	10,000,000	18	1,300	2,500	
29	2,500,000	5,000,000	17	640	1,300	
28	1,300,000	2,500,000	16	320	640	
27	640,000	1,300,000	15	160	320	
26	320,000	640,000	14	80	160	
25	160,000	320,000	13	40	80	
24	80,000	160,000	12	20	40	
23	40,000	80,000	11	10	20	
22	20,000	40,000	10	5	10	
21	10,000	20,000	9	2.5	5	
20	5,000	10,000	8	1.3	2.5	
19	2,500	5,000	7	.64	1.3	
			6	.32	.64	



SAMPLING PROCEDURE

Obtaining a fluid sample for analysis involves important steps to make sure you are getting a representative sample. Often erroneous sampling procedures will disguise the true nature of system cleanliness levels. Use one of the following methods to obtain a representative system sample.

- I. For systems with a sampling valve
- A. Operate system for at least 1/2 hour.
- B. With the system operating, open the sample valve allowing 200 ml to 500 ml (7 to 16 ounces) of fluid to flush the sampling port. (The sample valve design should provide turbulent flow through the sampling port.)
- C. Using a wide mouth, pre-cleaned sampling bottle, remove the bottle cap and place in the stream of flow from the sampling valve. Do NOT "rinse" out the bottle with initial sample.
- D. Close the sample bottle immediately. Next, close the sampling valve. (Make prior provision to "catch" the fluid while removing the bottle from the stream.)
- E. Tag the sample bottle with pertinent data; include date, machine number, fluid supplier, fluid number code, fluid type, and time elapsed since last sample (if any).

II. Systems without a sampling valve

There are two locations to obtain a sample in a system without a sampling valve: in-tank and in the line. The procedure for both follows:

- A. In the Tank Sampling
- 1. Operate the system for at least 1/2 hour.
- 2. Use a small hand-held vacuum pump to extract sample. Insert sampling device into the tank to one half of the fluid height. You will probably have to weight the end of the sampling tube. Your objective is to obtain a sample in the middle portion of the tank. Avoid the top or bottom of the tank. Do not let the syringe or tubing came in contact with the side of the tank.
- 3. Put extracted fluid into an approved, precleaned sample bottle as described in the previous sampling valve method.
- 4. Cap immediately.
- 5. Tag with information as described in sampling valve method.
- B. In-line Sampling
- 1. Operate the system for at least 1/2 hour.
- Locate a suitable valve in the system where turbulent flow can be obtained (ball valve is preferred). If no such valve exists, locate a fitting which can be easily opened

to provide turbulent flow (tee or elbow).

- Flush the valve or fitting sample point with a filtered solvent. Open valve or fitting and allow adequate flushing. (Take care to allow for this step. Direct sample back to tank or into a large container. It is not necessary to discard this fluid.)
- 4. Place in an approved, pre-cleaned sample bottle under the stream of flow per sampling valve methods.
- 5. Cap sample bottle immediately.
- Tag with important information per the sampling valve method. Note: Select a valve or fitting where the pressure is limited to 200 PSIG (14 bar) or less.

ON-SITE FLUID ANALYSIS PRODUCT



